

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0026:233 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Model 4098-9838 smoke detector guard. Unit is intended to be installed over separately listed Model 4098-9714 smoke detector (CSFM Listing No. 7272-0026:218) and Models 4098-9789, 4098-9791 or 4098-9792 base (CSFM Listing No. 7300-0026:217) to provide physical protection for the unit. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a detector guard for use with separately listed compatible detector and base as described under "DESIGN".

*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 13, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager